



CITY OF HIDALGO

PWS ID # TX1080021



2023 ANNUAL DRINKING WATER QUALITY REPORT

We are pleased to present our annual water quality report conducted between January 1 and December 31, 2023. We continue our commitment of providing you with the best drinking water, with reliable water pressure and at an affordable cost. Our staff works hard every day to distribute the best quality drinking water without interruption. As our city continually grows, we are diligently seeking new treatment technologies and production capacities to plan for future growths demands. We will keep citizens abreast via public outreach on our city web page and social media. Please know that we are always available, if you have any questions or concerns about your water.

ESTE INFORME INCLUYE INFORMACION IMPORTANTE SOBRE EL AGUA POTABLE. SI TIENE PREGUNTAS O COMENTARIOS SOBRE ESTE INFORME, FAVOR DE LLAMAR AL TELEFONO (956) 843-2286- PARA HABLAR CON UNA PERSONA BILINGUE.

CITY OF HIDALGO



SUPERIOR PUBLIC WATER SYSTEM

The City of Hidalgo has been designated by the Texas Commission on Environmental Quality (TCEQ) as a superior public water system in view of the high standards of water made available to the residents of Hidalgo. For over 20 years we have been recognized as a Superior Public Water Supply System, which achieves and maintains recognition for those systems who exceed the minimum acceptable standards of the TCEQ.



CITY OF HIDALGO



Where Do We Get Our Drinking Water?

The source of drinking water used by City of Hidalgo is ground water. From January 1 to December 31, we purchase surface treated water from the City of McAllen, (TCEQ PWS No. 1080006) on an as needed basis for emergency use. The McAllen water system obtains its source water from the Rio Grande river and some of their water quality data can be found at the end of this report.

For any questions about the City of McAllen's water quality, please contact the utility at (956) 681-4000.

More About Our Source Water & Treatment

The City of Hidalgo obtains its water source from the Gulf Coast aquifer by several water wells. Our ground water source is free of organic material and is naturally filtered as it flows through porous layers of soils such as sand. We use only one treatment chemical. This chemical is chlorine similar to the product used in your home but purer and approved as a disinfectant for use in drinking water. Chlorine is added to protect and maintain water quality. We carefully monitor the amount of chlorine, adding the lowest quantity necessary to protect the safety of your water without compromising taste.

Staff maintains a series of storage tanks and pumps to pressurize the distribution system so the sanitized treated water is pumped to the City water towers and into your home or business.

CITY OF HIDALGO



SUBSTANCES THAT COULD BE IN WATER

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

CITY OF HIDALGO



EPA REGULATIONS

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

CITY OF HIDALGO



SOURCE WATER ASSESSMENT

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact Mr. Virgil Gonzalez, Deputy City Manager at (956) 843-2286.

LEAD IN HOME PLUMBING

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe drinking water hotline or at <http://www.epa.gov/safewater/lead>.

CITY OF HIDALGO



Community Participation

DATE: JULY 1- 31,2024

TIME: 8:00AM-5:00 PM

LOCATION: HIDALGO CITY HALL

704 EAST RAMON AYALA DR.

HIDALGO, TX 78557

PHONE: (956) 843-2286; FAX:(56) 843-2317

WEBSITE: WWW.CITYOFHIDALGO.NET

TO LEARN ABOUT FUTURE PUBLIC MEETINGS (CONCERNING YOUR DRINKING WATER), OR TO SCHEDULE ONE, PLEASE CALL (956) 843-2286.

REPORT NOW ONLINE

THE 2023 DRINKING WATER QUALITY REPORT FOR CITY OF HIDALGO WATER SUPPLY CUSTOMERS IS NOW AVAILABLE ONLINE.

STARTING JULY 1, 2024, YOU WILL BE ABLE TO VIEW THE CITY OF HIDALGO ANNUAL WATER QUALITY REPORT ON-LINE AT:

[HTTPS://CITYOFHIDALGO.NET/PUBLIC-WORK](https://CITYOFHIDALGO.NET/PUBLIC-WORK)

CITY OF HIDALGO



WATER QUALITY TEST RESULTS

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/20/2022	1.3	1.3	0.13	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	09/20/2022	0	15	1.1	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2023	15	12.3 - 14.7	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

Total Trihalomethanes (TTHM)	2023	38	34.1 - 37.7	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	------	----	-------------	-----------------------	----	-----	---	--

*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year

CITY OF HIDALGO

WATER QUALITY TEST RESULTS



Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
*Arsenic	05/25/2022	5.5	0 - 5.5	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	05/25/2022	0.0245	0.0212 - 0.0245	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2023	0.92	0.9 - 0.92	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2023	0.09	0 - 0.09	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	05/25/2022	14.9	0 - 14.9	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.

*While your drinking water meets EPA standards for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

CITY OF HIDALGO



WATER QUALITY TEST RESULTS

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	12/18/2020	8.2	8.2 - 8.2	0	50	pCi/L*	N	Decay of natural and man-made deposits.
*EPA considers 50 pCi/L to be the level of concern for beta particles.								
Gross alpha excluding radon and uranium	12/18/2020	5	5 - 5	0	15	pCi/L	N	Erosion of natural deposits.
Uranium	12/18/2020	8.9	8.9 - 8.9	0	30	ug/l	N	Erosion of natural deposits.
Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chlorine	2023	1.01	0.23 – 1.56	4	4	ppm	N	Water additive used to control microbes.

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	1	0	0	N	Naturally present in the environment.

CITY OF HIDALGO

Definitions & Abbreviations



Definitions and Abbreviations	The tables in this report contain scientific terms and measures, some of which may require explanation.
Action Level:	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

	Definitions and Abbreviations
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	Million fibers per liter (a measure of asbestos)
mrem:	millirems per year (a measure of radiation absorbed by the body)
na:	not applicable.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picrocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion
ppm:	milligrams per liter or parts per million
ppq	parts per quadrillion, or picograms per liter (pg/L)
ppt	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

CITY OF HIDALGO



Water Conservation

The City of Hidalgo plans to update the Water Conservation and Drought Contingency Plan during summer to manage and provide an adequate water supply to meet the future needs of our customers. The purpose of this plan is to establish procedures to identify, classify, and manage an effective and efficient water supply during high water demand or water shortage emergency.

Summer Watering 2024

Water conservation protects the integrity of our water supply facilities and prolongs the life of existing water sources. The City reminds all customers to voluntarily conserve water and use water more efficiently. Our highest water usage is during the summer months for outdoor uses. A quick way to reduce your water consumption is to water your yard only when needed and to promptly fix all water leaks. Lastly, the best time to water is before noon or after 7 p.m. Customers can save money by purchasing water-efficient appliances and fixtures.

CITY OF HIDALGO



The City of Hidalgo continuously strives to provide our customers with the best drinking water and with adequate reliable water pressure.

As a result, we have a state approved interconnection with the city of McAllen public utilities board (TCEQ PWS No. 1080006). This ensures our customers are provided with access to a secondary water source during emergencies.

The water quality data provided by this water system is as follows:

City of McAllen 2023 Water Quality Report

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2023	2	0 - 2.1	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	2023	0.0856	0.0645 - 0.0856	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Cyanide	2023	100	80 - 100	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.
Fluoride	2023	0.6	0.54 - 0.6	4.0	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2023	0.18	0.06 - 0.18	10.0	10.0	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	2023	< 3	< 3	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.

CITY OF HIDALGO



City of McAllen 2023 Water Quality Report

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	2023	6.8	6.8 - 6.8	0	50	pCi/L*	N	Decay of natural and man-made deposits.
Uranium	04/25/2023	1.9	1.9 - 1.9	0	30	ug/l	N	Erosion of natural deposits.

*EPA considers 50 pCi/L to be the level of concern for beta particles.

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al teléfono (956) 843-2286.